

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - June, 2014

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
5	31	579.64	0.03	0.02	0.01	0.04	0.06	0.03	No
6	1	579.61	0.03	0.02	0.01	0.02	0.04	0.02	No
6	2	579.60	0.03	0.02	0.01	0.02	0.03	0.02	No
6	3	579.57	0.03	0.02	0.01	0.02	0.02	0.02	No
6	4	579.55	0.03	0.02	0.01	0.03	0.02	0.02	No
6	5	579.53	0.03	0.02	0.01	0.03	0.03	0.02	No
6	6	579.50	0.03	0.02	0.01	0.03	0.03	0.02	No
6	7	579.47	0.02	0.02	0.01	0.02	0.03	0.02	No
6	8	579.44	0.02	0.01	0.01	0.02	0.02	0.02	No
6	9	579.43	0.03	0.01	0.01	0.02	0.02	0.01	No
6	10	579.39	0.02	0.02	0.01	0.02	0.02	0.01	No
6	11	579.33	0.03	0.01	0.01	0.02	0.02	0.01	No
6	12	579.29	0.03	0.02	0.01	0.02	0.02	0.02	No
6	13	579.26	0.03	0.02	0.01	0.04	0.03	0.02	No
6	14	579.22	0.01	0.02	0.01	0.03	0.03	0.02	No
6	15	579.19	0.01	0.01	0.01	0.02	0.03	0.02	No
6	16	579.16	0.00	0.01	0.01	0.02	0.03	0.01	No
6	17	579.12	0.00	0.00	0.00	0.03	0.03	0.01	No
6	18	579.09	0.00	0.00	0.00	0.02	0.03	0.00	No
6	19	579.06	0.00	0.00	0.00	0.02	0.03	0.00	No
6	20	579.03	0.00	0.00	0.00	0.02	0.02	0.00	No
6	21	578.98	0.00	0.00	0.00	0.02	0.02	0.00	No
6	22	578.95	0.00	0.00	0.00	0.02	0.02	0.00	No
6	23	578.92	0.00	0.00	0.00	0.02	0.02	0.00	No
6	24	578.89	0.00	0.00	0.00	0.02	0.02	0.00	No
6	25	578.86	0.00	0.00	0.00	0.02	0.02	0.00	No
6	26	578.77	0.00	0.00	0.00	0.02	0.02	0.00	No
6	27	578.68	0.00	0.00	0.00	0.02	0.02	0.00	No
6	28	578.64	0.00	0.00	0.00	0.02	0.02	0.00	No
6	29	578.60	0.00	0.00	0.00	0.02	0.02	0.00	No
6	30	578.57	0.00	0.00	0.00	0.02	0.02	0.00	No

Total Monthly Target:	174,493 gallons
Total Monthly Actual:	466,100 gallons