

City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - September, 2015

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day Average Bypass Actual Flow (cfs)	3-day Average Bypass Target Flow (cfs)	Reservoir Spilling (yes/no)
8	31	564.58	0.02	0.03	0.02	0.02	0.02	0.03	No
9	1	564.46	0.03	0.02	0.01	0.02	0.02	0.03	No
9	2	564.32	0.01	0.03	0.02	0.06	0.03	0.03	No
9	3	564.18	0.02	0.01	0.01	0.07	0.05	0.02	No
9	4	564.01	0.03	0.02	0.01	0.07	0.07	0.02	No
9	5	563.97	0.03	0.03	0.02	0.06	0.06	0.02	No
9	6	563.93	0.02	0.03	0.02	0.07	0.07	0.03	No
9	7	563.89	0.02	0.02	0.01	0.06	0.06	0.03	No
9	8	563.87	0.01	0.02	0.01	0.06	0.07	0.02	No
9	9	563.71	0.01	0.01	0.01	0.07	0.06	0.02	No
9	10	563.56	0.01	0.01	0.01	0.05	0.06	0.01	No
9	11	563.42	0.02	0.01	0.01	0.03	0.05	0.01	No
9	12	563.39	0.02	0.02	0.01	0.04	0.04	0.01	No
9	13	563.36	0.02	0.02	0.01	0.05	0.04	0.02	No
9	14	563.34	0.02	0.02	0.01	0.05	0.04	0.02	No
9	15	563.23	0.03	0.02	0.01	0.05	0.05	0.02	No
9	16	563.10	0.01	0.00	0.00	0.05	0.05	0.01	No
9	17	563.04	0.06	0.00	0.00	0.05	0.05	0.01	No
9	18	562.91	0.07	0.00	0.00	0.05	0.05	0.00	No
9	19	562.86	0.07	0.00	0.00	0.05	0.05	0.00	No
9	20	562.77	0.06	0.00	0.00	0.05	0.05	0.00	No
9	21	562.64	0.08	0.00	0.00	0.05	0.05	0.00	No
9	22	562.50	0.03	0.00	0.00	0.06	0.05	0.00	No
9	23	562.36	0.04	0.00	0.00	0.06	0.05	0.00	No
9	24	562.23	0.05	0.00	0.00	0.05	0.06	0.00	No
9	25	562.08	0.06	0.00	0.00	0.06	0.06	0.00	No
9	26	562.02	0.05	0.00	0.00	0.06	0.06	0.00	No
9	27	562.00	0.05	0.05	0.04	0.06	0.06	0.02	No
9	28	561.97	0.04	0.05	0.04	0.06	0.06	0.03	No
9	29	561.85	0.04	0.04	0.03	0.05	0.06	0.05	No
9	30	561.69	0.02	0.00	0.00	0.06	0.06	0.03	No
Total Monthly Target:				277,897 gallons					
Total Monthly Actual:				1,046,200 gallons					