

**City of Calistoga Monthly Summary of the Kimball Reservoir Bypass - March, 2018**

Month	Day	Water Surface Elevation (ft)	5-day Average Inflow (cfs)	Bypass Target Flow (cfs)	70% of Bypass Target Flow (cfs)	Bypass Actual Flow (cfs)	3-day	3-day	Reservoir Spilling (yes/no)
							Average Bypass Actual Flow (cfs)	Average Bypass Target Flow (cfs)	
2	28	574.88	0.32	0.20	0.14	0.21	0.20	0.19	No
3	1	575.02	0.57	0.19	0.13	0.21	0.21	0.20	No
3	2	576.30	2.33	0.34	0.24	0.21	0.21	0.24	No
3	3	577.80	7.26	1.40	0.98	14.37	4.93	0.64	Yes
3	4	577.80	10.35	3.20	2.24	15.34	9.97	1.65	Yes
3	5	577.74	10.77	3.20	2.24	2.73	10.81	2.60	No
3	6	577.67	11.11	3.20	2.24	3.29	7.12	3.20	No
3	7	577.56	9.87	3.20	2.24	3.26	3.09	3.20	No
3	8	577.42	5.40	3.20	2.24	3.24	3.26	3.20	No
3	9	577.28	2.72	3.20	2.24	2.82	3.11	3.20	No
3	10	576.87	2.72	1.63	1.14	4.58	3.55	2.68	No
3	11	576.75	2.38	1.63	1.14	1.97	3.12	2.15	No
3	12	576.72	2.09	1.43	1.00	1.66	2.74	1.56	No
3	13	576.75	1.99	1.25	0.88	1.59	1.74	1.44	No
3	14	577.94	3.49	1.19	0.83	1.31	1.52	1.29	No
3	15	578.69	4.47	2.09	1.46	1.29	1.39	1.51	No
3	16	579.38	5.82	2.68	1.88	2.82	1.80	1.99	No
3	17	579.68	8.94	3.20	2.24	14.77	6.29	2.66	Yes
3	18	579.66	10.87	3.20	2.24	12.05	9.88	3.03	Yes
3	19	579.61	10.10	3.20	2.24	6.39	11.07	3.20	Yes
3	20	579.56	9.33	3.20	2.24	3.70	7.38	3.20	Yes
3	21	579.68	8.51	3.20	2.24	3.21	4.43	3.20	No
3	22	581.44	52.61	3.20	2.24	223.51	76.81	3.20	Yes
3	23	580.81	50.22	3.20	2.24	3.35	76.69	3.20	No
3	24	581.64	54.58	3.20	2.24	21.10	82.65	3.20	Yes
3	25	581.59	56.51	3.20	2.24	13.41	12.62	3.20	Yes
3	26	581.53	56.91	3.20	2.24	6.55	13.69	3.20	Yes
3	27	581.64	13.69	3.20	2.24	20.53	13.50	3.20	Yes
3	28	581.61	16.89	3.20	2.24	16.19	14.43	3.20	Yes
3	29	581.57	13.53	3.20	2.24	11.11	15.95	3.20	Yes
3	30	581.53	12.28	3.20	2.24	6.94	11.41	3.20	Yes
3	31	581.49	11.86	3.20	2.24	4.18	7.41	3.20	Yes

**Total Monthly Target:** 52,367,420 gallons

**Total Monthly Actual:** 276,403,078 gallons